



Cleanroom[®] Suitable Materials

Ergomat A/S
Report No. ER 1211-620

Ergomat Infinity Bubble
Particle (vs. PA6): ISO 6

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated below, provided by

Ergomat A/S
Søndersø, Denmark

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ER 1211-620.

Ergomat Infinity Bubble (color: black) was tested regarding particle emission during the application of frictional stress according to VDI 2083-17. The tested material obtained the following classification:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Ergomat Infinity Bubble; color: black	vs. PA6	ISO Class: 6
Reel-on-disc test Normal force 300 N		

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, June 26, 2013

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.